

PRODUCT PERFORMANCE REPORT

Document ID 1448828298

Issued on November 29th, 2015

PROJECT IDENTIFICATION - This product performance report is delivered for:

Name **janti**
Project reference **janti**
Project location **Finland**

PRODUCT IDENTIFICATION

Certification Diploma N° **94.01.135**
Brand **TOSHIBA**
Range **DSK 8**
Product reference **RAS-35G2AVP-ND/RAS-35G2KVP-ND**

Important notice:

- I. Data featured in this report are valid at the date of issue. The scope of this product performance report does not include all certified data that can be checked at <http://www.eurovent-certification.com>
- II. This product performance report is valid only for above product features and should not be referred to as a Diploma.

FEATURE	VALUE	UNIT
Acoustic		
LwO env	63	dB(A)
Lw1 env	58	dB(A)
Cooling		
Pdesignnc	3.5	kW
SEER	8.9	
SEER Class	A+++	
Qce	138.0	kWh/y
EER @+35	4.27	
General		
Mounting	High Wall	
MPS	230-1-50	
Refr. Line	5.0 m	m
Refrigerant	R410A	
Heating		
Pdesignnh	4.0	kW
SCOP	4.9	
SCOP Class	A++	
Qhe	1143.0	kWh/y
Tbiv	-7	C
Ph @Tbiv	4.0	kW
COP @Tbiv	2.65	
TOL	-25	C
Ph @ TOL	2.5	kW
COP @TOL	2.0	
Ph @+7	4.0	kW



PRODUCT PERFORMANCE REPORT

Document ID 1448828298

Issued on November 29th, 2015

FEATURE	VALUE	UNIT
COP @+7	5.0	
Power input in other modes		
Poff	1.0	W
Psb	1.0	W
Pto	31.0	W